

APPENDIX A

REQUIREMENTS FOR DEAD-END FIRE APPARATUS ACCESS ROADS (Ord. 2011-30)

Dead-end fire apparatus access roads in excess of 150 feet shall be proved with width and turnaround provisions as indicated below.

ROAD LENGTH (feet)

0-150	None required
151-500	22' road widths required and turnaround as indicated below
501-750	22' road widths required and turnaround as indicated below
Over 750	Special approved required

